



ई - नगर पालिका, मध्य प्रदेश शासन E-Nagar Palika, Government of Madhya Pradesh

Check Status and Download Fire NOC Certificate

Please Enter Search Details

Please Enter Registration No.

Fire NOC Application Current Status Details

Application No.

Applicant Name

Current Status of the Application

Remarks(If Any)



CERTIFICATE

This is to certify that we had carried out complete inspected internally and externally to Fire Extinguisher and certificate issue to :-

M/s. Shree Vaishnav Academy

Address: 170, Soth Rajmohalla, Indore

Testing & Inspection Report of fire Extinguisher

Year of Contract	2021-2022	Date-28/09/2021
Certificate No.	FNT/IND/21-22/TSD/16242	
Completion Month	September -2021	
Valid Up to	September -2022	
Warranty for	01-Year	
Details of New/Refilled fire extinguisher	ABC Type Capacity-6 Kgs	4 Nos.
	Total Quantity	4 Nos.
Inspection Details Of fire Extinguisher	<ol style="list-style-type: none">1. Check for proper sizes, types, quantity and placement of fire extinguishers. Ensure that each fire extinguisher is properly mounted, conspicuously located, not obstructed by objects and readily available for use in case of a fire.2. Make sure the instruction label is legible and facing outward.3. Check to be sure the extinguisher is fully pressurized, and/or at its full charged weight. Make sure the fire extinguisher hose is intact and free from obstruction.4. Operate the pull pin or locking device and install a new tamper seal. Check for dents, corrosion or other signs of damage.5. Look for any modifications to the fire extinguisher that could possibly reduce its functionality.6. Verify that the extinguisher is current on all internal maintenance and pressure testing requirements.7. Attach an updated tag or label as a record of proper maintenance.	
Declaration	We further certify that (FIRE NET) has successfully checked above fire extinguisher which is in good & working condition but necessary periodical maintenance, services and refill when required to fire extinguisher will be done by us.	

Technical service Department

Head Office : 182/1336, Malhar Nagar, No. 1, Off. Sajal Tower, Goregoan (W) Mumbai 400104 (M.H.)
Branch Office : Jay Vengal Complex, Opp. HP Petrol Pump Judges Bungalow Rd, Bodakdev, Ahmedabad- 380054
Ph.: 079-48410963, Mob.: 96875 33366, 96875 33977 Email: ahmedabad@firenetindia101.com

Signature of the inspector





CERTIFICATE

This is to certify that we had carried out complete inspected internally and externally to Fire Extinguisher and certificate issue to :-

M/s Shree Vaishnav Academy

Address: Rajmohalla, Indore (M.P.)

Testing & Inspection Report of fire Extinguisher

Year of Contract	2021-2022	Date-16/08/2021
Certificate No.	FNT/IND/21-22/TSD/15910	
Completion Month	August -2021	
Valid Up to	August -2022	
Warranty for	01-Year	
Details of New/Refilled fire extinguisher	ABC Type - Capacity-6 Kgs.	7 Nos.
	Total Quantity	7 Nos.
Inspection Details Of fire Extinguisher	<ol style="list-style-type: none">1. Check for proper sizes, types, quantity and placement of fire extinguishers. Ensure that each fire extinguisher is properly mounted, conspicuously located, not obstructed by objects and readily available for use in case of a fire.2. Make sure the instruction label is legible and facing outward.3. Check to be sure the extinguisher is fully pressurized, and/or at its full charged weight. Make sure the fire extinguisher hose is intact and free from obstruction.4. Operate the pull pin or locking device and install a new tamper seal. Check for dents, corrosion or other signs of damage.5. Look for any modifications to the fire extinguisher that could possibly reduce its functionality.6. Verify that the extinguisher is current on all internal maintenance and pressure testing requirements.7. Attach an updated tag or label as a record of proper maintenance.	
Declaration	We further certify that (FIRE NET) has successfully checked above fire extinguisher which is in good & working condition but necessary periodical maintenance, services and refill when required to fire extinguisher will be done by us.	

Technical service Department

Head Office : 192/1536, Motilal Nagar, No. 1, Off. Sajal Tower, Goregoan (W) Mumbai 400104 (M.H.)
Branch Office : 1, Jay Mangal Complex, Opp. HP Petrol Pump Judges Bungalow Rd, Bodakdev, Ahmedabad- 380054
Ph.: 079-48410888, Mob.: 99875 33366, 99875 33377 Email: ahmedabad@firenetindia101.com

Signature of the inspector



CERTIFICATE

This is to certify that we had carried out complete inspected internally and externally to Fire Extinguisher and certificate issue to :-

M/s- Shree Vaishnav Academy

Address: Rajmohalla, Indore (M.P.)

Testing & Inspection Report of fire Extinguisher

Year of Contract	2020-2021	Date-04/01/2021
Certificate No.	FNT/IND/20-21/TSD/14343	
Completion Month	January -2021	
Valid Up to	January -2022	
Warranty for	01-Year	
Details of New/Refilled fire extinguisher	ABC Type- Capacity-6 kgs.	10 Nos.
	Total Quantity	10 Nos.
Inspection Details Of fire Extinguisher	<ol style="list-style-type: none">1. Check for proper sizes, types, quantity and placement of fire extinguishers. Ensure that each fire extinguisher is properly mounted, conspicuously located, not obstructed by objects and readily available for use in case of a fire.2. Make sure the instruction label is legible and facing outward.3. Check to be sure the extinguisher is fully pressurized, and/or at its full charged weight. Make sure the fire extinguisher hose is intact and free from obstruction.4. Operate the pull pin or locking device and install a new tamper seal. Check for dents, corrosion or other signs of damage.5. Look for any modifications to the fire extinguisher that could possibly reduce its functionality.6. Verify that the extinguisher is current on all internal maintenance and pressure testing requirements.7. Attach an updated tag or label as a record of proper maintenance.	
Declaration	We further certify that (FIRE NET) has successfully checked above fire extinguisher which is in good & working condition but necessary periodical maintenance, services and refill when required to fire extinguisher will be done by us.	

Technical service Department

Head Office : 32/1533, Motilal Nagar, No.1, Off. Sajal Tower, Goregoan (W) Mumbai 400104 (M.H.)
Branch Office : Mangal Complex, Opp. HP Petrol Pump Judges Bungalow Rd, Bodakdev, Ahmedabad- 380054
Ph.: 079-49710983, Mob.: 86675 33366, 96675 33377 Email: ahmedabad@firenetindia101.com

Signature of the inspector



कार्यालय उप पुलिस महानिरीक्षक, अग्निशमन सेवायें, मध्यप्रदेश.

क्रमांक/उमनि/अशसे/ई/एनओसी/112- F /03-04

इन्दौर,

दिनांक 10/02/2004

प्रति,

✓ सचिव,

श्री वैष्णव एकेडमी,

177, साऊथ राजमोहल्ला,

इन्दौर ।

विषय:- अनापत्ति प्रमाण पत्र दिये जाने के संबंध में ।

संदर्भ:- आपका आवेदन पत्र दिनांक 11.12.2003 एवं पत्र दिनांक 30 जनवरी 2003

--x--

कृपया आपके संदर्भित पत्रों का अवलोकन करने का कष्ट करें। आपकी संस्था ने केन्द्रीय शिक्षा मण्डल, दिल्ली हेतु मान्यता प्राप्त करने के लिये इस विभाग की ओर से अनापत्ति प्रमाण पत्र चाहा है। इस संबंध में दिनांक 08.01.2004 को पुलिस अग्निशमन सेवा विभाग की समिति के द्वारा आपकी संस्था का निरीक्षण किये जाने के पश्चात् आपकी संस्था में निम्नलिखित अग्निशमन व्यवस्था अनिवार्य रूप से किये जाने के संबंध में पत्र क्रमांक/उमनि/अशसे/ई/एनओसी/112-बी/2004 दिनांक 12.1.2004 द्वारा निर्देश दिये गये है:-

1. ए.डी.एम.ब्लॉक/प्रिन्सीपल ऑफिस:- डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 1 नग,
2. केमेस्ट्री सेल:-
 - ॥ए॥ डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 1 नग,
 - ॥बी॥ सीओ2 गैस फायर एक्सटिंग्यूसर क्षमता 4.5 के.जी. 1 नग,
3. किचन:-
 - ॥ए॥ डीसीपी फायर एक्सटिंग्यूसर 5 के.जी. 1 नग,
 - ॥बी॥ डीसीपी फायर एक्सटिंग्यूसर क्षमता 10 के.जी. 1 नग,
4. स्टॉफ रूम सैकण्ड फ्लोअर/एल.पी.जी. कनेक्शन:-
 - डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 1 नग,
5. प्रेयर हाऊस/हॉल:-
 - ॥ए॥ डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 1 नग,
 - ॥बी॥ वाटर सीओ2 फायर एक्सटिंग्यूसर क्षमता 9 लीटर 2 नग,
 - ॥सी॥ सीओ2 गैस फायर एक्सटिंग्यूसर क्षमता 4.5 के.जी. 1 नग,
6. पावर पेनल:-
 - ॥ए॥ डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 1 नग,
 - ॥बी॥ सीओ2 गैस फायर एक्सटिंग्यूसर क्षमता 4.5 के.जी. 1 नग,
7. कम्प्यूटर लेब:-
 - ॥ए॥ डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 1 नग,
 - ॥बी॥ सीओ2 गैस फायर एक्सटिंग्यूसर क्षमता 4.5 के.जी. 1 नग,
8. फिजीक्स लेब:-
 - डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 1 नग,

१२१

9. बायलोजी लेब:- डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 1 नग,
10. ग्राऊण्ड फ्लोअर स्टेअर केस:- डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 2 नग,
11. फर्स्ट फ्लोअर स्टेअर केस:- डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 2 नग,
12. सेकण्ड फ्लोअर स्टेअर केस:- डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 2 नग,
13. सेकण्ड फ्लोअर लायब्रेरी:- डीसीपी फायर एक्सटिंग्यूसर क्षमता 5 के.जी. 1 नग,
14. पानी व बाबूरेती के 3-3 नग बकेट्स मय स्टेण्ड,
15. वीस हजार १२०,००० लीटर पानी के भण्डारण का टेंग.

उपरोक्त प्रस्तावित आई.एस.आई. मार्क पंचिंग एवं उच्च गुणवत्ता की फायर फायटिंग व्यवस्था से सहमत होते हुए इसका पालन किये जाने वाबत आपने अपने संदर्भित पत्र दिनांक 30 जनवरी 2004 द्वारा सहमति दी है। अतः उपरोक्तानुसार सरल क्रमांक-01 से 14 तक की समस्त फायर फायटिंग व्यवस्था आपकी संस्था/श्री वैष्णव एकेडमी, 177 साऊथ राजमोहल्ला इंदौर में अनिवार्य रूप से किये जाने की शर्त पर अनापत्ति प्रमाण पत्र प्रदाय किया जाता है। प्रस्तावित व्यवस्था को लागू करने में किसी प्रकार की कमी पायी जाने पर पुलिस अग्निशमन सेवा विभाग अपनी एन.ओ.सी. को निरस्त करने के लिये स्वतंत्र रहेगा।

पुलिस महानिरीक्षक, अग्निशमन सेवायें, म. प्र. द्वारा अनुमोदित



:एम. अरुणा राव:

उप पुलिस महानिरीक्षक,
अग्निशमन सेवायें, मप्र. इंदौर।